

SHRI A.P.D.JAIN PATHASHALA

WALCHAND GROUP OF EDUCATION, SOLAPUR

E- TENDER

SHRI A.P.D.JAIN PATHASHALA

WALCHAND GROUP OF EDUCATION, SOLAPUR

Tender Document for Supply & Installation of LT Panel, 100 KVAR 12 Stage APFC Panel, with fabricated work , APP Type Heavy Duty Oil Filled Capacitors 440V AC & Blue Star make 38 TR Air Cooled Scroll Chiller

1. Name of Bidder:

2. Full Address:

3. Mobile No/e-mail ID:

4. PAN Number:

5. Experience

6. Terms & condition are:

Whether acceptable or not

7. Client list with contact No. :

Above document Attach With technical bid

Authorized Signatory:

Name:

Designation:

SHRI A.P.D.JAIN PATHASHALA

WALCHAND GROUP OF EDUCATION, SOLAPUR

Tender Document for Supply & Installation of LT Panel, 100 KVAR 12 Stage APFC Panel, with fabricated work , APP Type Heavy Duty Oil Filled Capacitors 440V AC & Blue Star make 38 TR Air Cooled Scroll Chiller.

The detail of tender is as follows.

E- Tender Time Table

1	e-Tender Publishing Date	Date: - 01/03/2026 Time 12 PM
2	Tender Document Download & Submission Start Date and Time	Date: - 01/03/2026 Time 12 PM
3	Closing date and time of Tender	Date: - 08/03/2026 Time 05 PM
4	Date and place of opening of E-Tender Document (Technical Bid Opening Date)	Date: - 09/03/2026 Time 05 PM Walchand Institute of Technology, Solapur. Walchand Hirachand Marg, Ashok chowk, Solapur.

Terms & conditions:

1. Valid GST Number and HSN code of product must be mentioned on quotation.
2. You should must be submitted UDYAM certificate, GST Certificate& shop act license copy
3. Conditional and unsigned quotation will not be accepted.
4. Incomplete quotation or received after due date shall be rejected.
5. The quotation shall not contain correction, erasers and overwriting, it will result in rejection of quotation
6. The rates of items must be quoted according to full specification as per requirement along with all terms and conditions.
7. Quotation should reach by hand, by post or by e-Mail within 8 **Days** from the publication of this notice.
(E-Mail Id- witstore.solapur@gmail.com)
8. Quotation should be stamped and signed on supplier letterhead.
9. The quotation should include all types of taxes and transportation.
10. The Institute reserves all the rights to accept or reject any / all quotation and to increase or decrease quantity or quality of items specified without specifying any reason.
11. Quotation to be submitted/ delivered at address-**Walchand College of Arts & Science (Autonomous), Solapur. (Central Store)** / Walchand Hirachand Marg, Ashok chowk, Solapur, Maharashtra- 413006.

12. Panel is required following quality material fabricate 16/18 swg CRCA sheet, powder coated, Self Standing with 40 x 5 Angle Stand of Ht 500mm and also Panel is required internal control & Power wiring, Aluminum Busbar of rated current capacity.

Tender Document for Supply & Installation of LT Panel, 100 KVAR 12 Stage APFC Panel, with fabricated work , APP Type Heavy Duty Oil Filled Capacitors 440V AC & Blue Star make 38 TR Air Cooled Scroll Chiller.

Main LT Panel for New Machine, Details

Sr.No	Item	Make	Qty	Unit
	Incoming Side			
1	DN3 400N(400A)50KATP MCCB with ROM ,Sp. link, S/h Coil & Aux Trip Alarm Contact for Main Incoming	LK	01	Set
2	Digital Multi fuction Meter VIF	Elmeasure	01	No
3	CT 400/5Afor VIF Meter	Veritek	03	No
4	Control MCB for Backup	C&S	03	No
5	LED Type RYB Indicators for Mains & ON+OFF +TRIP	Esbee	06	No
6	SPD FP Type1+2, I imp 12.5ka,I max 50ka with 63A FPI solator for Backup protection	LK	01	No
7	Digital Earth Fault Relay MC 31 a (3 over current + EF R)	LK	01	No
	Outgoing Side			
1	DN3 400N(315A)50 KATP MCCB with ROM ,Sp .link for O/g	LK	01	Set
2	DN1 250C(200A)25 KATP MCCB with ROM ,Sp .Link for APFC	LK	01	Set
3	DN0125D(125A)36 KATP MCCB with ROM ,Sp. link for O/g	LK	01	Set
4	DN0100D(100A)36 KATP MCCB with ROM ,Sp. link for O/g	LK	02	Set
5	40ATP MCB“C” Curve	LK	02	No
6	Base Framein 75x40mm C Channel	-	1	No
7	Panel Approx size :1900mm(H)x1600mm(W)x450mm(D)			
	Unite Rate			

100 KVAR 12 Stage APFC Panel Details

Sr.No	Item	Make	Qty	Unit
	Incoming Side			
1	16 Stage APFC Relay eta ULTRA16R3 CT Relay	LK	01	Set
2	CT400/5A for APFC Relay	Veritek	3	No
3	LED Indicator for Supply Indication	Esbee	3	No
4	6A SPMCB for Backup protection	C&S	3	No
5	Aluminium Busbar40x10x1Electrolite	Hindalco	1	Set
	Outgoing Side			
1	16ATP MCB+MOC 3 Cont.for2K,3k Cap.	LK	4	No
2	16ATP MCB+MOC5 Cont.for05KCap.	LK	4	No

3	25A TP MCB+MOC 10for10KCap	LK	1	No
4	32A TP MCB+MOC 15for15KCap	LK	1	No
5	63A TP MCB+MOC 20for20KCap	LK	1	No
6	63A TP MCB+MOC 25for25KCap	LK	1	No
7	Auto/Manual SS for Relay	Salzer	1	No
8	Auto/Manual Actuator22.5mm for Individual Step Auto/Man	Esbee	12	No
9	Control & Power wiring	-	-	-
10	02KVARAPP Type Heavy Duty Capacitor	Prabodhan	2	No
11	03KVARAPP Type Heavy Duty Capacitor	Prabodhan	2	No
12	05KVARAPP Type Heavy Duty Capacitor	Prabodhan	4	No
13	10KVARAPP Type Heavy Duty Capacitor	Prabodhan	1	No
14	15KVARAPP Type Heavy Duty Capacitor	Prabodhan	1	No
15	20KVARAPP Type Heavy Duty Capacitor	Prabodhan	1	No
16	25KVARAPP Type Heavy Duty Capacitor	Prabodhan	1	No
	Unite Rate			

APP Type Heavy Duty Oil Filled Capacitors 440V AC make- Prabodhan

Sr. No	Item	Qty	Rate	Amount
1	2KVAR	1No		
2	3KVAR	1No		
3	5KVAR	2No		
4	7.5KVAR	2No		
5	10KVAR	3No		
			Total	
			18%GST	
			Total	

Blue Star make 38 TR Air Cooled Scroll Chiller

Sr. No	Item	Qty	Rate	Amount
1	Supply of BLUE STAR make Air Cooled Star Rated Scroll Chiller with CHW Inlet 12 Deg C and Outlet 7 Deg C AS per attached Technical Data Sheet Model No: XAC2YS-038MAR3	01		

Chilled Water Piping

Sr. No	Description	UOM	QTY	Rate	Amount
1	Supply and Installation of CHW Pipeline 80 MM Dia	RMT	24		
2	SITC of 80 MM Dia Butter Fly Valves	Nos	2		
3	SITC of Pressure Gauges	Nos	6		
4	SITC of Dial Type Thermometer	Nos	6		
5	Expansion Bellows for flexible Connections	Nos	4		
6	SITC of Balancing Valve	Nos	3		
7	SITC of 80 MM Dia Butter Fly Valves	Nos	6		
8	SITC of Ball valves for drain Point	Nos	6		
9	Auto Air Vents	Nos	2		
10	SITC of Chilled Water Pump with 100 USGPM @30 M Head	Nos	1		
11	Un loading, Lifting shifting of Chiller and Pumps	Lot	1		

TERMS & CONDITIONS:

- **Rates Comparison :**

Bidders are requested to send their rates (inclusive of transportation, loading, unloading, GST etc, nothing extra will be paid and free delivery and installation) on FOR, On Site.

- **Spares:**

The spare parts/wear & tear consumables, if any, required for trouble free operation of equipment to be quoted separately giving the full nomenclature, rate, quantity and shelf life of each item.

- **Delivery & Installation:**

All the goods ordered shall be delivered and installed at Permanent Campus of the Institute, Walchand Hirachand Marg Ashok Chowk Solapur; as mentioned in the purchase order all the aspects of safe delivery and commissioning shall be the exclusive responsibility of the supplier. If the supplier fails to deliver and commissioning of the goods on or before the stipulated date, then a penalty at the rate of 1% per week of the total order value shall be levied subject to

maximum of 10% of the total order value. The goods are to be supplied within this stipulated period, failing which the supply order is liable to be cancelled

- **Satisfactory Installation:**

Satisfactory installation / commissioning and handing

Over of the equipment mean the faultless functioning of the equipment for a minimum period of 30 days after satisfactory installation.

- **Safety measures:**

The contractor should take safety measures during the panel installation you should use all safety equipments

- **Guarantee / Warranty:**

One year Guaranty has to be provided by the firm from the date of the satisfactory installation / commissioning of panel against the defect of any manufacturing. In case, there is any variation in the warranty as per the specification of the item equipment, the warranty as specified in the specifications shall be final.

- **Acceptance of Terms & Conditions:**

Bidders must confirm the acceptance of all the terms and conditions of this NIQ. Any non-acceptance or deviations from the terms and conditions must be clearly mentioned. However, tender are must note carefully that any conditional offer or any deviation from the terms and conditions of this NIQ may render the quotation liable for rejection. SAPDJ PATHASHALA does not bind itself to accept the lowest of any tender and reserves the right to reject any or all tenders without assigning any reason.

Note: The Secretary, SAPDJ PATHASHALA Solapur reserves the right to accept/reject any or all tenders without assigning any reasons thereof and also to reject.

- **Jurisdiction:**

The courts at Solapur alone will have the jurisdiction to try any matter, dispute or reference between parties arising out of this tender / contract. It is specifically agreed that no court outside and other than Solapur court shall have jurisdiction in the matter.